


# Example of useful **AHU Modbus BYP**



<b>Black</b>	Value/Status
<b>Green</b>	Setpoints/Command
<b>Red</b>	Alarm
<b>Blue</b>	Actual setpoint-value

## **BYP**

### **Plate heat exchanger**

ST4	3x0036	Heat recovery output signal
GM1	3x0090	Room humidity relative (%)
GT4:1	4x0148	Cold corner
GT4:2	3x0076	Extract air temperature