

## **STZ-01-C-00-1 MODULATING DAMPERS, SUPPLY AND EXTRACT AIR**

Modulating dampers controlled by an analog output. Dampers operates on demand, humidity, air quality or temperature.

Can be used in both heating and cooling sequence.

Dampers open on heating demand if supply air is warmer than room/extract air temperature.

Dampers open on cooling demand if supply air is cooler than room/extract air temperature.